

LABELING NOTES

- 1.1 LABELING REQUIREMENTS BASED ON THE 2017 NATIONAL ELECTRICAL CODE, INTERNATIONAL FIRE CODE 605.11, OSHA STANDARD 1910.145, ANSI Z535
- 1.2 MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
- 1.3 LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED.
- 1.4 LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8" AND PERMANENTLY AFFIXED.
- 1.5 ALERTING WORDS TO BE COLOR CODED. "DANGER" WILL HAVE RED BACKGROUND; "WARNING" WILL HAVE ORANGE BACKGROUND; "CAUTION" WILL HAVE YELLOW BACKGROUND. [ANSI Z535]

WARNING

ELECTRICAL SHOCK HAZARD
TERMINALS ON THE LINE AND
LOAD SIDES MAY BE ENERGIZED
IN THE OPEN POSITION

LABEL 1

AT EACH DISCONNECTING MEANS FOR
PHOTOVOLTAIC EQUIPMENT (2" X 4").
[NEC 690.13].

WARNING

POWER SOURCE
OUTPUT CONNECTION
DO NOT RELOCATE THIS
OVERCURRENT DEVICE

LABEL 2

AT POINT OF INTERCONNECTION
OVERCURRENT DEVICE (2" X 4").
[NEC 705.12(B)(2)(3)(B)].

PHOTOVOLTAIC SYSTEM AC DISCONNECT

RATED AC OUTPUT CURRENT **PSCMC** A
NOMINAL OPERATING AC VOLTAGE **TSV** V

LABEL 3

AT POINT OF INTERCONNECTION, MARKED
AT DISCONNECTING MEANS (4" X 2").
[NEC 690.54]

PHOTOVOLTAIC SOLAR AC DISCONNECT


LABEL 4
AT EACH AC DISCONNECTING MEANS
(4" X 1").
[NEC 690.13(B)].

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

LABEL 5

AT RAPID SHUTDOWN DISCONNECT SWITCH (5 1/4" X 2").
[NEC 690.56(C)(3)].

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN



TURN RAPID SHUTDOWN switch TO THE
"OFF" POSITION TO SHUT DOWN PV
SYSTEM AND REDUCE SHOCK HAZARD
IN ARRAY

LABEL 6

AT RAPID SHUTDOWN SYSTEM
(3 3/4" X 5 1/4"). [NEC 690.56(C)(1)(A)].

WARNING

DUAL POWER SUPPLY
SOURCES: UTILITY GRID
AND PV SOLAR
ELECTRIC SYSTEM

LABEL 7

AT POINT OF INTERCONNECTION
(2 3/4" X 1 5/8").
[NEC 705.12(B)(3)]

WARNING

SOLAR ELECTRIC
CIRCUIT BREAKER
IS BACKFED

LABEL 8

AT POINT OF INTERCONNECTION
(2" X 1").
[NEC 705.12(B)(3)]

INTERACTIVE PHOTOVOLTAIC SYSTEM CONNECTED
PHOTOVOLTAIC SYSTEM DISCONNECT LOCATED
SW SIDE OF THE HOUSE

DIRECTORY

PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE
DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM DISCONNECTING
MEANS IF NOT IN THE SAME LOCATION (5 3/4" X 1 1/8").

[NEC 690.56(B)]

WHERE THE PV SYSTEMS ARE REMOTELY LOCATED FROM EACH OTHER, A
DIRECTORY IN ACCORDANCE WITH 705.10 SHALL BE PROVIDED AT EACH PV
SYSTEM DISCONNECTING MEANS.

PV SYSTEM EQUIPMENT AND DISCONNECTING MEANS SHALL NOT BE INSTALLED IN
BATHROOMS
[NEC 690.4(D),(E)]

WARNING: PHOTOVOLTAIC POWER SOURCE

LABEL 9

AT EXPOSED RACEWAYS, CABLE TRAYS, AND OTHER WIRING
METHODS; SPACED AT MAXIMUM 10 FT SECTION OR WHERE
SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS,
OR FLOORS (5 3/4" X 1 1/8").

[NEC 690.31(G)]

LETTERS AT LEAST 3/8 INCH; WHITE ON RED BACKGROUND;
REFLECTIVE
[IFC 605.11.1.1]

CAUTION

SOLAR ELECTRIC SYSTEM CONNECTED

LABEL 10

AT UTILITY METER (5 3/4" X 1 1/8")
[NEC 690.56(B)]